



FAKOLITH Farben GmbH  
Report No. FA 1803-1018

# Cleanroom<sup>®</sup> Suitable Materials

DISPERLITH ELASTIC  
Biological Resistance: excellent

## FLOORING & COATING

### Biological Resistance

### Qualification Certificate

DUPLICATE

We hereby certify that the material stated above, provided by

FAKOLITH Farben GmbH  
Fürth, Germany

has been awarded the Fraunhofer IPA CSM Certificate of Qualification with the report number FA 1803-1018.

The CSM classification of the DISPERLITH ELASTIC according to biological resistance is based on a worst-case consideration of both procedures A and C. Therefore growth intensity according to ISO 846 and VDI 2083 Part 18 has been transferred to the following classification:

Biological resistance	Growth intensity	Classification
Fungi (Procedure A)	0	excellent
Bacteria (Procedure C)	0	excellent
<b>Overall result</b>	<b>0</b>	<b>excellent</b>

This document only applies to the named product in its original state and is valid for a period of 5 years from the date the first document was issued. The document can be verified under [www.tested-device.com](http://www.tested-device.com).

Detailed information and parameters of the test environment can be found in the Fraunhofer IPA test report.

FA 1803-1018  
Report No. first document  
--  
Report No. current document

Stuttgart, April 13, 2018  
Place, date of first document issued  
--  
Place, current date

on behalf of   
Dr.-Ing. Udo Gommel, Project Manager Fraunhofer IPA